

# Airport Hangar Inspection Checklist

Fire and Life Safety sample checklist for airport hangars.

---

## Electrical

- Discontinue use of extension cords in lieu of permanent wiring.
- Discontinue use of multi-plug adapters in series.
- Remove extension cords through openings, affixed to buildings, or attached in series.
- Maintain wiring in good condition and protect from damage.
- Discontinue use of wiring not in conduit.
- Provide cover plates.
- Replace all damaged/spliced electrical wiring.
- Electrical panel and equipment shall have a minimum of 36" clearance front, 30" sides and 76" height.

## Exiting and Housekeeping

- Flammable liquids must be stored in original containers or closed metal cans.
- Store any rubbish exceeding the capacity of a 5-gallon bucket in an approved container.
- Provide 30" clearance from heat producing appliances and combustible material.
- Remove combustible storage, waste, trash or weeds.
- Remove or store waste material and oily rags in approved/listed closed metal container.
- Provide metal drip pans located under the engines of all aircraft.
- Provide and post NO SMOKING signs.

## Fire Protection

- Extinguishers must be serviced every 6 years and inspected annually
- Extinguishers must be accessible and located appropriately.
- Maintain integrity of occupancy and area separation walls.

## Storage

- Remove storage from exits, aisles, corridors, and under stairs.
- Reduce storage height to at least 2 feet below ceiling in buildings not protected by sprinklers.
- Secure and identify compressed gas cylinders.

